

Seneca County Department of Health  
Environmental Services  
2465 Bonadent Drive, Suite 3 , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection -- Summary Report

Operation: The Kountry Stop - water (ID: 754825)  
Facility Name: The Kountry Stop  
Facility Code: 49-3568 Facility Email: None  
Facility Address: 4477 Route 96A Geneva, NY 14456

To the Attention of:

Owner/Operator Email: None

### Sanitary Survey

Date: APR 02, 2019 01:00 PM  
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)  
Responsible Person: habeal morales  
(email: )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected: 0  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

**NO VIOLATIONS WERE OBSERVED.**

Code Requirements

Inspector Findings

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - None; Source Type - Not indicated; 4- Log Treatment installed - Not indicated; Coliform surveillance sample collected - No ;

Comments

END of REPORT

[Submit# 499995] The Kountry Stop - water (ID754825) Inspection#

1002426267