

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Campground Inspection -- Summary Report

Operation: BLUE HERON BAY MARINA (ID: 564205)
Facility Name: BLUE HERON BAY MARINA
Facility Code: 495872 Facility Email: GLAUN33@YAHOO.COM
Facility Address: 634 WATERLOO GENEVA ROAD WATERLOO, NY 13165

To the Attention of:
ROBERT STIVERS 5 & 20 MARINE
PO BOX 91
GENEVA , NY 14456- Owner/Operator Email: bstivers1@hotmail.com

Inspection

Date: JUN 01, 2017 11:34 AM
Inspector: Melissa Brown (mbrown@co.seneca.ny.us)
Responsible Person: TO BE MAILED
(email:)

Summary

Number of public health hazards found: 5
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

PUBLIC HEALTH HAZARDS

A public health hazard is any condition that poses an imminent threat to the health or safety of the public. An owner/operator of a regulated facility must immediately correct all public health hazards or take actions to prevent exposure to the hazard.

ITEM # 7 WAS FOUND IN VIOLATION 5 TIME(S). PUBLIC HEALTH HAZARD

All or parts of the violation item are IN violation.

Code Requirements

Absence of cross connections - potable water supply {7-3.5(b)(1)(vii)}

Inspector Findings

Sites 7,9,10,11,12 have a hose attached to the black water outlet. This is not allowed. These attachments MUST be removed. Direct connection into the on-site waste water disposal system is acceptable. Re-inspection to be conducted.

OTHER

ITEM # 51 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Utility sinks - adequate, location, maintained

Inspector Findings

No utility sink found on premiss

Additional Information Collected During Inspection

Comments

Entrance/exit to premises has pot holes.

END of REPORT

[Submit# 289813] BLUE HERON BAY MARINA (ID 564205) Inspection# 1001971630