

Seneca County Department of Health
Environmental Services
31 Thurber Drive , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Mobile Home Park Inspection -- Summary Report

Operation: BROOKSIDE MOBILE HOME PARK (ID: 308311)
Facility Name: BROOKSIDE MOBILE HOME PARK
Facility Code: 49-AJ64 Facility Email: None
Facility Address: CHAPIN STREET

To the Attention of:
STEPHEN W BULL
3324 FALLBROOK
CANANDAIGUA , NY 14424- Owner/Operator Email: None

Inspection

Date: JUN 01, 2017 02:17 PM
Inspector: Melissa Brown (mbrown@co.seneca.ny.us)
Responsible Person: mailed
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

FIRE SAFETY

ITEM # 21 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the violation item are IN violation.

Code Requirements

Separation Distances Adequate {17.5(b)}

Inspector Findings

Separation distances are not adequate due to additions made on to homes. Porches/decks have decreased the distance between homes.

Additional Information Collected During Inspection

Comments

END of REPORT

[Submit# 290127] BROOKSIDE MOBILE HOME PARK (ID 308311) Inspection# 1001971948