

## Swimming Pool Inspection Summary Report

Operation: Babcock Hovey - Outdoor Pool (ID: 308214 )  
Facility Name: BABCOCK-HOVEY BSA  
Facility Code: 49-0019 Facility Email: don.declerck@scouting.org  
Facility Address: 7294 County Road 132 Road, Ovid, NY 14521

### To the Attention of:

Steve Hoitt  
SENECA WATERWAYS COUNCIL, BSA  
2320 Brighton Henrietta Townline Rd  
Rochester, NY 14623  
Email: don.declerck@scouting.org

### Inspection

Date: July 15, 2019 04:27 PM  
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)  
Responsible Person: Eric Panetta

### Summary

Number of Public Health Hazards Found:	1
Number of Public Health Hazards NOT Corrected:	0
Number of Other Violations Found:	0

---

*Each item found in violation is reported below along with the code requirement.*

## PUBLIC HEALTH HAZARDS

### ITEM # 2 WAS FOUND IN VIOLATION 1 TIME(S). PUBLIC HEALTH HAZARD

*Part or parts of the item were observed to be in violation which were corrected at the time of inspection.*

**Code Requirements:** Minimum Disinfectant Residual Provided {6-1.4(b)(2)}

**Inspector Findings:** bromine at 0  
CORRECTED: CLOSED POOL UNTIL MINIMUM BROMINE LEVEL OF 1.5mgL

---

## NO NON-PUBLIC HEALTH HAZARDS REPORTED

---

**Additional Information Collected During Inspection**

Supervision Level at Time of Inspection:      IIb

Temporary Residence / Campground:          No

**Water Chemistry**                      **Disinfectant: Chlorine**

**Comments:** Pool is closed until minimum disinfection of 1.5 bromine is achieved

---



---

Inspector: Julie Hoster (jhoster@co.seneca.ny.us)



---

Received by: Eric Panetta