

Swimming Pool Inspection Summary Report

Operation: CAMP BABCOCK-HOVEY CUB SCOUTS OUTDOOR POOL (ID: 809916)
Facility Name: CAMP BABCOCK-HOVEY CUB SCOUTS
Facility Code: 49-1322 Facility Email: DON.DECLERCK@SCOUTING.ORG
Facility Address: 7294 County Road 132 , Ovid, NY 14521

To the Attention of:

Steve Hoitt
SENECA WATERWAYS COUNCIL
2320 Brighton Henrietta Townline Rd
Rochester, NY 14623
Email: don.declerck@scouting.org

Inspection

Date: August 5, 2019 02:14 PM
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)
Responsible Person: Trish Brewer

Summary

Number of Public Health Hazards Found:	0
Number of Public Health Hazards NOT Corrected:	0
Number of Other Violations Found:	2

Reinspection is not Required

Each item found in violation is reported below along with the code requirement.

NO PUBLIC HEALTH HAZARDS REPORTED

POOL OPERATION & MAINTENANCE

ITEM #34 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the item are violations.

Code Requirements: Water Quality; Pool Clarity, Bottom/Slides Clean, Water Surface {6-1.19, 6-1.10(k)}

Inspector Findings: pool cloudy; grate visible

POOL OPERATION & MAINTENANCE

ITEM #38 WAS FOUND IN VIOLATION 1 TIME(S).

All or parts of the item are violations.

Code Requirements: Disinfection Treatment/Chemical Treatment {6-1.11(c), (d), 6-1.25(c), 6-1.19(c)}

Inspector Findings: bromine @10mg/L pool closed until residual falls below 6mg/L

Additional Information Collected During Inspection

Supervision Level at Time of Inspection: III

Temporary Residence / Campground: No

Water Chemistry **Disinfectant: Chlorine**

Free Cl/Br (mg/L) 10

Comments:



Inspector: Julie Hoster (jhoster@co.seneca.ny.us)



Received by: Trish Brewer