

Seneca County Department of Health  
Environmental Services  
31 Thurber Drive , Waterloo,, NY 13165  
(315) 539 - 1945  
jbates@co.seneca.ny.us

## Public Water Supply Inspection -- Summary Report

Operation: The Kountry Stop - water (ID: 754825)  
Facility Name: The Kountry Stop  
Facility Code: 49-3568 Facility Email: None  
Facility Address: 4477 Route 96A Geneva, NY 14456

To the Attention of:

Owner/Operator Email: None

### Sanitary Survey

Date: MAR 01, 2017 02:52 PM  
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)  
Responsible Person: Kelley Ryan  
(email: )

### Summary

Number of public health hazards found: 0  
Number of public health hazards NOT corrected: 0  
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

**NO VIOLATIONS WERE OBSERVED.**

### Code Requirements

### Inspector Findings

### Additional Information Collected During Inspection

Water System Information: Type of disinfection - UV; Source Type - Not indicated; 4- Log Treatment installed - No; Coliform surveillance sample collected - Yes, collection time 2:33pm, from Utility CWT; Chlorine residual - 0 mg/l, collection time 2:30pm from Utility CWT;

### Comments

Total Coliform water sample taken.  
Nitrate water sample taken.

END of REPORT

[Submit# 270640] The Kountry Stop - water (ID 754825) Inspection# 1001946252