

Seneca County Department of Health
Environmental Services
2465 Bonadent Drive, Suite 3 , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Public Water Supply Inspection -- Summary Report

Operation: The Kountry Stop - water (ID: 754825)
Facility Name: The Kountry Stop
Facility Code: 49-3568 Facility Email: None
Facility Address: 4477 Route 96A Geneva, NY 14456

To the Attention of:

Owner/Operator Email: None

Sanitary Survey

Date: MAR 28, 2018 02:57 PM
Inspector: Arthur Sinicropi (asinicropi@co.seneca.ny.us)
Responsible Person: Kelly Ryan
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 0

Each item found in violation is reported below along with the code requirement.

NO VIOLATIONS WERE OBSERVED.

Code Requirements

Inspector Findings

Additional Information Collected During Inspection

Water System Information: Type of disinfection - None; Source Type - Not indicated; 4- Log Treatment installed - Not indicated; Coliform surveillance sample collected - No ;

Comments

Total Coliform water sample taken. Nitrate water sample taken. Well is properly capped and found in good condition. Ultra violet disinfection system was inspected and found in good condition.

END of REPORT

[Submit# 374730] The Kountry Stop - water (ID754825) Inspection# 1002285098