

Seneca County Department of Health
Environmental Services
2465 Bonadent Drive, Suite 3 , Waterloo,, NY 13165
(315) 539 - 1945
jbates@co.seneca.ny.us

Temporary Residence Inspection -- Summary Report

Operation: HOTEL (ID: 961456)
Facility Name: DEL LAGO RESORT & CASINO
Facility Code: 49-1133 Facility Email: CHRIS.BASIL@DELLAGORESORT.COM
Facility Address: 1133 ROUTE 414 WATERLOO, NY 13165

To the Attention of:
LAGO RESORT & CASINO LLC
1133 ROUTE 414
WATERLOO , NY 13165- Owner/Operator Email: jeff.babinski@dellagoresort.com

Inspection

Date: JUN 08, 2018 03:32 PM
Inspector: Julie Hoster (jhoster@co.seneca.ny.us)
Responsible Person: Hicham Jaddoud
(email:)

Summary

Number of public health hazards found: 0
Number of public health hazards NOT corrected: 0
Number of other violations found: 1

Each item found in violation is reported below along with the code requirement.

FIRE SAFETY

ITEM # 29 WAS FOUND IN VIOLATION 1 TIME(S).

Part or parts of the violation item were observed to be in violation which were corrected at the time of inspection.

Code Requirements

Vertical/horizontal confinement - existing building features maintained as designed {7-1.8(f)}

Inspector Findings

area of refuge call not answered by security when activated

Additional Information Collected During Inspection

Comments

END of REPORT

[Submit# 395951] HOTEL (ID 961456) Inspection# 1002329063